ift-Nachweis

Classification Report

Number	20-002040-PR01 (NW-A01-02-en-01)
Owner	FEAL d.o.o. Trnska cesta 146 88220 Siroki Brijeg Bosnia and Herzegovina
Product	Sliding projecting, top-hung casement
Designation	Shipping name: 50 FK
Details	Manufacturer FEAL d.o.o., - Siroki Brijeg; Material Aluminium system with thermal break; Type of opening Sliding projecting, top-hung casement; Opening direction Outwards; Overall dimensions (W x H) 1330 mm x 1480 mm
Special features	Test sequence, locking part in internal drainage, Locking points under maximum hold

Result

Air permeability according to EN 12207:2016-12

Class: 4

Resistance to wind load according to EN 12210:2016-03

Class: C5/B5

Watertightness according to EN 12208:1999-11

Class: E1050

ift Rosenheim
05.06.2020

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Maximilian Denkl
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions (e.g. DIN EN)

Test report: 20-002040-PR01 PB-A01-02-en-01

Representation

Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check

www.ift-rosenheim.de/ift-geprueft
ID: B27-4CFD3

ift Rosenheim GmbH
Theodor-Gietl-Str. 7-9
D-83026 Rosenheim

Contact
Phone: +49 8031 261-0
Fax: +49 8031 261-290
www.ift-rosenheim.de

Testing and Calibration – EN ISO/IEC 17025
Inspection – EN ISO/IEC 17020
Product Certification – EN ISO/IEC 17065
Certification of Management Systems – EN ISO/IEC 17021

Notified Body 0757
PÜZ-Stelle: BAY 18

ilac-MRA DAkkS Deutsche Akkreditierungsstelle D-PL-11349-01-00